

**RFP-2022-07-JAG**

**LOWER RICHLAND COMMUNITY CENTER RENOVATION**

**ADDENDUM 3**

**July 07, 2022**

**Q&A**

Clarification/Changes/Explanations:

1. When the two new walls are installed, the new offices will not have a light switch.
  - Do you want new light switches? ***No, the original switch will work***
2. When the two new offices are installed, the new offices will not a return air vent.
  - Do you want new return air vents? ***No.***
3. The scope of work doe's state the gauge of metal studs and track to use. The gauge is the density of the studs and we recommend a 20 gauge for a 9ft ceiling.
  - Do you want 25 gauge, 20 gauge or 18 gauge? ***New walls are to be 20-gauge metal studs and track.***

Attachments:

- 00310 Bid Form

Julia A. Gibbs  
Procurement Coordinator

